



## SEWER MAIN REHABILITATION PROJECT

TENDER 16-17

### ADDENDUM NO. 1

June 28<sup>th</sup>, 2016

**This addendum forms part of the Tender Documents** and shall be read, interpreted, and coordinated with all other parts. The costs of all elements contained herein shall be included in the submission. The following revisions, changes, corrections, additions, and or deletions supersede the information contained in the original Documents to the extent referenced and shall become part thereof.

#### **Addendum Item 1 Questions & Answers**

---

##### **1. Proponent Question:**

Regarding “**33 05 24 – 1.9.9 Type B: Reinstate Conn c/w Liner**”, it does not have a length required to line the service lateral, can you please clarify?

##### **Response:**

Payment for this line item “**Type B: Re-instate Conn. c/w liner**” is for reinstatement of the service lateral at the mainline only and is not intended to be used for service lateral re-lining and will be paid as per 33 05 24 item 1.9.9 with proponents directed to Supplementary Specification 33 05 24 item 3.8 for additional clarification on Execution. All references to Connection Liner or Approved Equivalent under Type B Service Connections, listed on drawings and in Schedule of Quantities and Prices, are no longer valid and will not be applied.

#### **End of Addendum**

**Acknowledgement of this Addendum in your Tender submission is required.**

Clinton J. Crook, SCMP, CPSM  
Senior Buyer